# Constraining Radon Backgrounds in LZ

Eric Miller

South Dakota School of Mines & Technology

On Behalf of the LZ Collaboration

5/25/17 LRT 2017








### The LZ Experiment





Successor of LUX and ZEPLIN Dark Matter experiments

Fiducial mass: 5.6 tonne liquid Xe


WIMP sensitivity better than 2.3x10<sup>-48</sup> cm<sup>2</sup> at 40 GeV

Located at the Sanford Underground Research Facility



#### Backgrounds in LZ





Most Probable (> 99.9%) decays from Radon

Background estimate for 1,000 livetime-days including discrimination and efficiencies:


Environmental	0.05
Argon + Krypton	0.13
<sup>210</sup> Bi Migration	0.20
Material Contamination	0.28
<sup>136</sup> Xe	0.34
Neutrinos	1.64
Radon & Daughters	3.49
Total	6.12

Radon migrates to fiducial volume; <sup>214</sup>Pb decays by untagged beta



#### Backgrounds in LZ





Background estimate for 1,000 livetime-days including discrimination and efficiencies:

Total	6.12
Radon & Daughters	3.49
Neutrinos	1.64
<sup>136</sup> Xe	0.34
Material Contamination	0.28
<sup>210</sup> Bi Migration	0.20
Argon + Krypton	0.13
Environmental	0.05


Radon migrates to fiducial volume; <sup>214</sup>Pb decays by untagged beta

LRT 2017 - Eric Miller



#### Backgrounds in LZ





Background estimate for 1,000 livetime-days including discrimination and efficiencies:

Total	6.12
Radon & Daughters	3.49
Neutrinos	1.64
<sup>136</sup> Xe	0.34
Material Contamination	0.28
<sup>210</sup> Bi Migration	0.20
Argon + Krypton	0.13
Environmental	0.05


Radon migrates to fiducial volume; <sup>214</sup>Pb decays by untagged beta

...or here...
or anywhere else in
contact with Xe!



#### Measuring Radon from Materials







#### Radon Screening Program for LZ



Planned screening for all materials in contact with Xe

Screening devices at 4 LZ institutions

63 measurements completed so far

System	Technology	Emanation Chamber Volume	Blank Rate	LZ Sample Throughput
UCL	Electrostatic PIN-diode	2.6 liters 2.6 liters	0.2 mBq 0.4 mBq	6 / year
UMD	Electrostatic PIN-diode	4.7 liters	0.2 mBq	12 / year
SDSM&T	Electrostatic PIN-diode	13 liters & 300 liters	<0.3 mBq ~0.3 mBq	18 / year
Alabama	Liquid Scintillator Coincidence	2x 2.6 liters	0.2 mBq	24 / year

LRT 2017 - Eric Miller



#### Instrument Cross-Calibration



- Each system already calibrated with radon source
- Plans to cross-calibrate all systems with at least two samples (blind)
  - One higher rate to calibrate efficiency w/o interference from backgrounds (rubber)
  - One lower rate to check understanding of backgrounds (thoriated rods)
- EXO Canadian collaborator J. Farine shared a rubber sample with UA to cross-calibrate systems.
- Measurements with 6/7 vessels agree on source strength within uncertainties
- Will begin sending around thoriated rods soon



The rubber sample in a chamber at UA



#### Preliminary Screening: PMT Cable



LZ to use over 17 km of PMT cabling
Screened 750 m sample of Axon cable
Preliminary measurement Results:

 $1.4 \pm 0.1 \, \text{mBq / km}$ 

 $1.4 \pm 0.2 \, \text{mBq / km}$ 





### Preliminary Screening: HV Feedthrus



LZ Will have 116 HV feedthroughs, each with 7 pins

Screened 5 samples from manufacturer

Preliminary measurement Results:

 $0.1 \pm 0.05$  mBq / feedthrough

0.08 ± 0.06 mBq / feedthrough





#### Preliminary Screening: PMT Bases



LZ Will have 625 PMTs in Xe space; therefore 625 PMT bases

Screened 100 bases post-production

Preliminary measurement Results:

 $0.28 \pm 0.17 \text{ mBq} / 100 \text{ bases}$ 

Component-wise assay suggests:

0.19 mBq / 100 bases





#### Preliminary Screening: PTFE





Approx 84 m<sup>2</sup> of PTFE in LZ

Screened 18 m<sup>2</sup> sample of skived material

Preliminary measurement Results:

 $< 0.015 \text{ mBq / m}^2$ 







# Preliminary Screening: Cathode HV Cable



LZ will have about 8 m of (very) high-voltage cable to provide power to cathode.


Screened 8 m sample of cable material

Preliminary measurement Results:

 $0.73 \pm 0.33 \, \text{mBq} / \text{m}$ 

 $0.26 \pm 0.06$  mBq / m (w/o ground braid)

This cable has been rejected, for a variety of reasons.





# Significant Preliminary Screening Results



Material	Result	Units	Contribution without mitigation	
PMT Cable - Axon	1.4 ± 0.1 1.4 ± 0.2	mBq / km	24 mBq 24 mBq	
PMT HV Feedthroughs	0.1 ± 0.05 0.08 ± 0.06	mBq / unit	12.2 mBq 9.8 mBq	
PMT Bases	0.28 ± 0.17	mBq / 100	1.8 mBq	
PTFE	< 0.015	mBq / m <sup>2</sup>	< 1.29 mBq	
Umbilical Cable (rejected)	0.73 ± 0.33 0.26 ± 0.06	mBq / m	5.6 mBq 2.1 mBq	

Sum of Rn production from all materials should be less than 10 mBq.


10 mBq expected from dust as well.



# Radon Mitigation: Epoxy on Feedthrough



Coat wetted side of ceramic feedthrough with epoxy to prevent migration of radon.



LRT 2017 - Eric Miller




#### Radon Mitigation: Carbon Trap



Radon can be removed from Xe with cooled carbon trap

Purification of full recirculation impractical, but can clean select regions:





#### Radon Mitigation: Temperature




Diffusion of radon slows at low temperature, following Arrhenius relation:

$$D = A \exp(-T/T_0)$$

This implies ~100x reduction of radon **diffusing** out of typical materials and into LZ (170K) relative to screenings (300K)

Surface effects, like emanation from recoils or dust, are unaffected by temperature





# Preliminary Screening Results After Mitigation



Material	Result	Units	Contribution	After Mitigation
PMT Cable - Axon	1.4 ± 0.1 1.4 ± 0.2	mBq / km	24 mBq	1.2 mBq
PMT HV Feedthroughs	0.05 ± 0.02 0.04 ± 0.03	mBq / unit	6.1 mBq 4.9 mBq	0.6 mBq 0.5 mBq
PMT Bases	0.28 ± 0.17	mBq / 100	1.8 mBq	< 1.8 mBq
PTFE	< 0.015	mBq / m <sup>2</sup>	< 1.29 mBq	< 1.29 mBq
Umbilical Cable (rejected)	0.73 ± 0.33 0.26 ± 0.06	mBq / m	5.6 mBq 2.1 mBq	

Sum of Rn production from all materials should be less than 10 mBq.

10 mBq expected from dust as well.



#### Preliminary Radon Estimate for LZ



Material	Component(s)	Quantity	Unit	Estimate (mBq)
Al <sub>2</sub> O <sub>3</sub> resistor	PMT Bases	9790	#	0.58*
BaTiO <sub>3</sub> capacitor	PMT Bases	3010	#	0.016*
Cirlex	PMT Bases	6000	cm <sup>2</sup>	0.37*
Titanium	Cryostat, PMT Mounts, Field Rings, Grid Supports	412,000	cm <sup>2</sup>	0.41
PTFE	Reflectors, HV Umbilical	840,000	cm <sup>2</sup>	<1.3*
PMT Cabling <sup>†</sup>	PMT Cabling	17,000	m	0.09
PMT Feedthrough <sup>†</sup>	Signal Flange	88	#	< 0.24
Steel Conduit <sup>†</sup>	Cabling Conduit	100,000	cm <sup>2</sup>	0.055
R11410 PMT	R11410 PMT	488	#	1.26
R8520 PMT	R8520 PMT	90	#	0.15
R8778 PMT	R8778 PMT	36	#	0.09
Polyethylene	HV Umbilical	4200	cm <sup>2</sup>	0.10
Tin-coated copper	HV Umbilical	11,000	cm <sup>2</sup>	0.002
Tivar	HV Umbilical	3894	cm <sup>2</sup>	0.004*
Acetal	HV Umbilical	195	cm <sup>2</sup>	0.0002*
Copper	HV Umbilical	39	cm <sup>2</sup>	0.000007
Ероху	HV Umbilical	1000	cm <sup>2</sup>	0.0001*
Steel	Cryostat Seals, Xe Recirculation	135,000	cm <sup>2</sup>	0.104
Recirculation Pump	Xe Recirculation	1	#	0.1
Purification Getter	Xe Recirculation	2.5	kg	1.34
Transducers & Valves	Xe Recirculation	30	#	0.17
Welds	Recirculation System, Cryostat	32.3	m	0.11
Dust			8	10.0
Total				<16.5

Table slightly updated from LZ TDR

Bo items are measured by collaboration

- \* items expected to reduce at low temperature
- t items whose Rn is mitigated by carbon trap:
- > 90% reduction.

LRT 2017 - Eric Miller



#### Summary



Most significant backgrounds in LZ likely to be from Rn daughters

Radon screening program underway for LZ, employing sensitive screeners at 4 institutions

We have identified some mitigation strategies for problematic materials

Satisfactory expectation of 6.5 mBq from materials, and 16.5 mBq total



## Questions?



